

ADDENDUM NUMBER TWO

To the Drawings and Project Manual

Dated: 21 February 2025

Entitled: IN000B Multi-Building Classroom Upgrades
(IU20240647)

Owner:
Trustees of Indiana University
Bloomington, IN 47408

Project Address:
Indiana University Indianapolis Campus

Prepared By:



Chris W. Lake, AIA

Indiana Registration No. AR10400187

Addendum Dated: 14 March 2025

Project Number: 24-060

CHANGES TO THE PROJECT MANUAL

1. None

CHANGES TO THE DRAWINGS

1. None

GENERAL CLARIFICATIONS/QUESTIONS

1. **Question:** Note 14 ED102, need clarification on what the “touchscreen” is. I don’t see anything in the lighting schedule. **Answer:** LCD Touchscreen Wattstopper EQ73-LCAP. Refer to Lighting Controls schedule for list of materials on drawing sheet E004.

END OF ADDENDUM NUMBER TWO

Attachments:

Engineers Addendum #2



Primary Engineering, Inc.
9785 Crosspoint Blvd., Ste. 103
Indianapolis, Indiana 46256
317-324-1221 ph
www.primary-eng.com



Addendum: **2**
Date: **03/14/2025**
Project: **2025 Multi-Classroom Project**
Comm #: **IU #20240647**

The following items shall be incorporated into the specifications and drawings and are considered to be integral to the bid documents for the project. Acknowledgement of receipt of this addendum is required on the bid form.

Item #1: General Questions:

- A. Question:** Note 14 ED102, need clarification on what the “touchscreen” is. I don’t see anything in the lighting schedule. **Answer:** LCD Touchscreen Wattstopper EQ73-LCAP. Refer to Lighting Controls schedule for list of materials on drawing sheet E004.