

BL577 – ROTC bldg. E8 – Decommissioning Central Chilled Water Plant – Add DX Cooling to E7

**Indiana University
Bloomington, Indiana
IU 20210422**

ADDENDUM NO. 2

HEAPY PROJECT NO. 2022-07232

June 10, 2025

GENERAL

ITEM NO. 1 Section 23 31 13 HVAC DUCTWORK – Section 2.5 – Line D

A. Change Hardcast DT Tape sealant to Hardcast CCWI-181 sealant.