
Addendum #01

Project: 20250132 - BL467 IU STUDENT HEALTH CENTER - RENOVATE 2ND & 4TH FL NURSING STATIONS & REPLACE INTERIOR SIGNAGE

Date: 01.16.2026

Interior Designer: White Pine Local, LLC, 812-826-3464, anna@whitepinelocal.com

This Addendum, issued prior to bidding, alters, amends, corrects, or clarifies the Construction Bid Documents to the extent stated herein and does thereby become a part of the Construction Bid Documents, and will become part of the Contract Documents of the successful bidder. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

ITEMS INCLUDED IN THIS ADDENDUM

Item 1: Question from bidder:

Question: Specs call for RB1 Resilient Wall Base to be 5". The specified manufacturer does not offer 5" height in the standard wall base.

Response: Please adjust RB1 to be 6"H. No other change to manufacturer or color.

END OF ADDENDUM