
Addendum #02

Project: 20250132 - BL467 IU STUDENT HEALTH CENTER - RENOVATE 2ND & 4TH FL NURSING STATIONS & REPLACE INTERIOR SIGNAGE

Date: 01.20.2026

Interior Designer: White Pine Local, LLC, 812-826-3464, anna@whitepinelocal.com

This Addendum, issued prior to bidding, alters, amends, corrects, or clarifies the Construction Bid Documents to the extent stated herein and does thereby become a part of the Construction Bid Documents, and will become part of the Contract Documents of the successful bidder. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

ITEMS INCLUDED IN THIS ADDENDUM

Item 1: Question from bidder:

Question: Door 234A is calling for a Hollow Metal Frame on the Door schedule on sheet I-301, however, Frame Elevation A2 on the same sheet is calling for an Aluminum Storefront Frame.

Response: Door 234A should have an aluminum storefront frame as shown in Elevation A2/I-301.

Item 2: Acceptable manufacturer:

An acceptable temporary construction barrier vendor is Temporary Wall Systems (TWS). This vendor is not required, but they are approved for this project.

END OF ADDENDUM