



Addendum 4

Owner Information	INDIANA UNIVERSITY
Contractor Information	N/A

DATE	02/04/2026
PROJECT NAME	BL572 – Intercollegiate Athletics Gymnasium – Replace Chiller, Heating Systems and Controls
INTROBA PROJECT #	2035.0013084
IU PROJECT #	20240613
DISTRIBUTION	Owner
ADDENDUM CONSIST OF	(1) 8.5 x 11 PAGE

The following additions, revisions, and modifications are part of the contract documents, which shall be amended accordingly. Acknowledge receipt of addenda on the bid form. Failure to acknowledge receipt of this addendum may result in the rejection of your offer.

SPECIFICATIONS

1. 235233 HYDRONIC BOILERS
 - a. Replaced as 2.2 C:
 - i. "C. Special Warranty: Manufacturer's standard form in which manufacturer warrants the heat exchanger against failure due to defects in materials or workmanship for 10 years. For the lifetime of the product, Manufacturer warrants the heat exchanger against failure due to thermal shock. For 5 years, Manufacturer warrants the burner against failure due to defects in materials or workmanship. All parts are warranted 24 months from substantial completion. This limited warranty is in effect when the product is installed within the United States or Canada, provided it remains at its original place of installation."

SIGNATURE Christopher Hawk

A handwritten signature in black ink that reads "Christopher Hawk".