



# HUTTON & HUTTON

ARCHITECTS & ENGINEERS

## Addendum-01

27 February 2026

To the Drawings and Specifications for:

**SB840 Wiekamp Hall - Restroom Remodel - IU# 20222221**

**Indiana University  
South Bend, Indiana**

IU Project #: 20222221

HHAЕ #: IUSB2501

Addendum Number One

### **TO ALL BIDDERS, PLAN HOLDERS OF RECORD AND REGULATORY AGENCIES:**

This Addendum supplements and amends the original and/or previously issued Construction Drawings and Project Manual, and shall be taken into account when preparing proposals, and shall become a part of the Contract Documents. Receipt of this Addendum must be acknowledged on the Proposal Form, failure to do so may subject the Bidder to being disqualified.

---

#### **GENERAL REQUIREMENTS**

---

- 1.01 Reference:** General Information - Prebid Meeting Agenda.
- A. Clarification:** Attached is the Prebid Meeting Agenda held on 12 February 2026.

---

#### **DRAWING ITEMS**

---

- 1.02 Reference:** Revised architectural sheet A1.1 - PARTIAL FIRST FLOOR DEMOLITION PLAN - NORTH RESTROOM with revision date 25 February 2026.
- A. Clarification:** Detail 1/A1.1 was revised to show larger extent for demolition work at corridor alcove where drinking fountain is located. Demolition Note #5 was added to identify scope of work at corridor alcove.
- 1.03 Reference:** Revised architectural sheet A1.2 - PARTIAL FIRST FLOOR DEMOLITION PLAN - SOUTH RESTROOM with revision date 25 February 2026.
- A. Clarification:** Detail 1/A1.2 was revised to show larger extent for demolition work at corridor alcove where drinking fountain is located. Demolition Note #5 was added to identify scope of work at corridor alcove.
- 1.04 Reference:** Revised architectural sheet A2.1 - PARTIAL FIRST FLOOR PLAN - NORTH RESTROOM with revision date 25 February 2026.
- A. Clarification:** Detail 5/A2.1 was revised to show the change in wall finishes in the corridor alcove/recess where drinking fountain is located.
- 1.05 Reference:** Revised architectural sheet A4.0 - INTERIOR ELEVATIONS with revision date 25 February 2026.

[info@hhaes.com](mailto:info@hhaes.com)  
6832 Calumet Avenue  
Hammond, Indiana 46324  
219.932.2050



Est. 1895

# Addendum-01

- A. **Clarification:** Detail 13/A4.0 was revised to show larger extent of new wall tile, wall base, and corner guards at drinking fountain alcove/recess. Interior Elevation Notes #18 and 19 were added.
- 1.06 **Reference:** Revised interior design sheet FO.0 – FINISH SCHEDULE AND DETAILS with revision date 25 February 2026.
- A. **Clarification:** The Finish Schedule was revised to change the wall finish product WT2, Porcelain Wall Tile to be Marazzi Illusionist IL50 Magical (for wall finish) and IL48 Smoke (for wall base). This resulted after HHAЕ, the Architect, has been informed that the previously specified wall finish product WT2 (Morello Collection Random Mosaic Amber MMO4) has been discontinued by the manufacturer.
- B. **Clarification:** Note #10 in the Finish General Notes was added to clarify the expected preparation work for the replacement of flooring to be done by the Contractor.
- 1.07 **Reference:** Revised interior design sheet F1.0 – PARTIAL FIRST FLOOR FINISH PLANS with revision date 25 February 2026.
- A. **Clarification:** Details 1 and 2/F1.0 were revised to show the change in wall finishes for the alcove/recess areas along corridors 1199C and 1299E. The new wall finishes have been changed to wall finish WT2 on all sides and to corner guards CG1 at outside corners.
- B. **Clarification:** Note #10 in the Finish General Notes was added to clarify the expected preparation work for the replacement of flooring to be done by the Contractor.

---

## RFI ITEMS

---

- 1.08 **Reference:** Contractor Question: *Looking at the drawings the wall that separates the toilet rooms. I think one side of that chase needs to come down, maybe not all of it, but at least 5' up. Especially with the alternate that wants to change the piping. And with the new flush valves being wired and the face plates being on the wall, How is the electrician going to be able to install his conduit for the flush valve hook ups? It may be less expensive than all the patching to be done. My opinion, from projects we have done in the past. If they could build a stud wall. I don't remember what the wall material is now, just throwing it out there. Might be something to consider.*
- A. **Clarification:** The demolition work at the existing chase wall between restrooms includes the removal of gypsum board layers and finishes and leaving the existing metal stud framing in place as per demolition note #12 [see details #1/A1.1 and #1/A1.2]. The Contractor may need to relocate the existing studs and bracing to install the new plumbing fixtures. Note, the Contractor is responsible for removing and replacing any portion of the existing chase wall construction including studs and bracing.
- 1.09 **Reference:** Contractor Question: *My Daltile representative has informed me that Restroom Field Tile (FT-1) Keystone Custom 2" Hexagon Pattern: Shamrock has been Discontinued. Can you please contact the Architect and owner and advise them a new selection will need to be made. **Additional statement by Contractor:** Update on the previous email. "I have just been notified by Daltile that (FT-1) Custom 2" Hex Pattern is still Discontinued, but Daltile will make it as a Special Custom Made-to-Order Pattern with a Lead time of [10-12 Weeks.]" Please confirm tile intentions.*
- A. **Clarification:** The Contractor shall have the option to either order the specified floor tile products FT1 and FT2 from Daltile as custom order products, or to order approved-as-equal, domestically sourced, floor tile products from another manufacturer. Refer to revision in Finish Schedule on sheet FO.0 [enclosed].



## END OF ADDENDUM NUMBER ONE

### Attachments:

#### Architectural Items:

Pre-Bid Meeting Agenda

Sheet A1.1 - PARTIAL FIRST FLOOR DEMOLITION PLAN - NORTH RESTROOM with revision date  
25 February 2026.

Sheet A1.2 - PARTIAL FIRST FLOOR DEMOLITION PLAN - SOUTH RESTROOM with revision date  
25 February 2026.

Sheet A2.1 - PARTIAL FIRST FLOOR PLAN - NORTH RESTROOM with revision date 25 February 2026.

Sheet A4.0 - INTERIOR ELEVATIONS with revision date 25 February 2026.

Sheet FO.0 - FINISH SCHEDULE AND DETAILS with revision date 25 February 2026.

Sheet F1.0 - PARTIAL FIRST FLOOR FINISH PLANS with revision date 25 February 2026.

JWH/jss





## INDIANA UNIVERSITY CAPITAL PROJECTS PRE-BID CONFERENCE AGENDA

Please visit the IU Plan Room, ([www.iuplanroom.com](http://www.iuplanroom.com)) to find out information on projects that are out for bids, how to obtain contract documents, a listing of plan holders, and addendums.

- Under “Site Options”, you can link to the “Bid Tabs & Awards” web site for the bid tabulation within 48 hours after bid opening.
- Questions – Contact: Justin Hutton (HHAЕ) at (219) 932-2050 or [jhutton@hhaes.com](mailto:jhutton@hhaes.com). IU: Kelly Reed, Project Manager and Senior Interior Designer at (317) 274-5353 or [kelreed@iu.edu](mailto:kelreed@iu.edu) - Aaron Hoover, Facilities Management at [aahoov@iu.edu](mailto:aahoov@iu.edu). 574-520-4319

### 1. Introductions:

- a. IU Capital Project Representative
- b. IU Construction Management Representative
- c. IU User Representative
- d. Consultant

### 2. Type of Bid:

- a. A Unified Bid is requested to include all General, Fire Protection, Plumbing, Mechanical and Electrical Work.
- b. Office of the Vice President for Capital Planning and Facilities  
Via electronic bid submission on [www.iuplanroom.com](http://www.iuplanroom.com). Bidders must be registered on the plan room, and signed into the plan room, in order to submit a bid. Bids will be electronically opened via Zoom: <https://iu.zoom.us/j/82623978895>  
Meeting ID: 826 2397 8895  
Join By Telephone: 312-626-6799  
2:00 P.M. EDT (Eastern Daylight Time),  
on Wednesday, March 4, 2026.
- c. Bidders must use the provided Bid Proposal form in the Project Manual.
- d. Include with the Bid Proposal the Form 96, Contractor Asbestos Certification, Asbestos Protocol for Contractors, Bid Security in the amount of 5% of the bid, and the Minority and Women’s Business Enterprise Participation Plan.
- e. If the bid or project estimate is over \$150,000.00 a written plan for a program to test the Contractor’s employees for drugs is required to be submitted with the bid in accordance with IC 4-13-8.


### 3. Base Bid, Allowances, Unit Prices and Alternate Bids (if any):

- a. Fill out the Bid Proposal form completely.
- b. Indicate Unit Prices as line items in the quantity indicated.
- c. No voluntary Alternates will be accepted. Bidders are required to provide what is called for in the documents. Product Substitutions will not be


considered except as outlined in the General Conditions.

4. All written questions pertaining to the Bid Documents must be received not later than five (5) calendar days before Bid Opening.
5. Addendum can be issued no fewer than two (2) calendar days before Bid Opening. Please check the [www.iuplanroom.com](http://www.iuplanroom.com) web site for addendum.
6. Project Temporary Facilities:
  - a. Job Site Office
  - b. Restrooms
  - c. Parking/Access to the Site
  - d. Site Security
  - e. Storage
7. Review of Tentative Construction Schedule:
  - a. Bid Opening Date: March 4, 2026
  - b. Contract Award – 1 week
  - c. Contractor's Insurance Approval – 3 weeks
  - d. Begin Work: See Bid Proposal for date
  - e. Complete Work: See Bid Proposal for date
8. Questions pertaining to General Conditions or "Front End" documents.
9. Description of Scope of Work.
10. Tour of Facilities.


**1** PARTIAL DEMOLITION FIRST FLOOR PLAN - NORTH RESTROOM  
3/8" = 1'-0"




**2** PARTIAL DEMOLITION FIRST FLOOR CEILING PLAN - NORTH RESTROOM  
3/8" = 1'-0"



- ### DEMOLITION NOTES
- EXISTING CONSTRUCTION TO REMAIN AND BE PROTECTED DURING CONSTRUCTION, THIS AREA.
  - EXISTING ACCESS PANEL (REFER TO EXTENTS OF RENOVATION DRAWINGS FOR ADDITIONAL INFORMATION).
  - REMOVE EXISTING CEILING ITEMS COMPLETE, THIS AREA (REFER TO MEP DRAWINGS FOR ADDITIONAL INFORMATION).
  - REMOVE EXISTING GYPSUM BOARD CEILING / SOFFIT, COMPLETE THIS AREA AS REQUIRED FOR NEW CONSTRUCTION.
  - REMOVE EXISTING WALL FINISH AND WALL BASE COMPLETE THIS AREA. PREPARE REMAINING SURFACES AS REQUIRED FOR APPLICATION OF NEW FINISHES (REFER TO FINISH DRAWINGS).
  - REMOVE AND DISPOSE OF EXISTING PLUMBING FIXTURES AND EXISTING TOILET ACCESSORIES COMPLETE. REPAIR ALL WALL PENETRATIONS AS REQUIRED. (REFER TO PLUMBING DRAWINGS).
  - REMOVE TOILET PARTITIONS AND STRUCTURAL SUPPORTS ABOVE IN ENTIRETY. STRUCTURAL COMPONENTS MAY REMAIN AS LONG AS THEY DO NOT IMPERE ANY NEW / EXISTING WORK. CONTRACTOR SHALL INCLUDE COST OF STRUCTURAL REMOVAL. NOTIFY ARCHITECT / OWNER DURING CONSTRUCTION OF INTENT TO REMOVE OR STAY PRIOR TO WORK.
  - REMOVE EXISTING FINISH FLOORING AND BASE COMPLETE THIS AREA. PREPARE REMAINING SURFACES AS REQUIRED FOR APPLICATION OF NEW FINISHES.
  - REMOVE AND DISPOSE OF EXISTING WALL MOUNTED AND RECESSED IN WALL CORNER GUARDS, HAND RAILS, TOILET ACCESSORIES, ETC. COMPLETE THIS AREA ON ALL WALLS INDICATED TO REMAIN AND SHIM COAT ALL AFFECTED SURFACES AS REQUIRED AND PREPARE SURFACES FOR APPLICATION OF NEW WALL FINISHES.
  - EXISTING FLOOR DRAIN TO REMAIN. REMOVE EXISTING DRAIN COVER. (REFER TO PLUMBING DRAWINGS FOR ADDITIONAL INFORMATION).
  - REMOVE AND DISPOSE OF EXISTING PLUMBING FIXTURE FOR INSTALLATION OF NEW FIXTURES. REPAIR ALL WALL PENETRATIONS TO MATCH EXISTING ADJACENT WALL SURFACES AND PREPARE SURFACES FOR APPLICATION OF NEW WALL FINISHES.
  - REMOVE EXISTING WALL TILE AND GYPSUM BOARD LAYERS COMPLETE TO METAL STUDS. DRAWINGS ASSUME NEW LAYER OF CEMENT BOARD AND / OR GYPSUM BOARD AND WALL TILE. (SEE A0.2 FOR PARTITION DETAILS).
  - REMOVE AND DISPOSE OF EXISTING DOORFRAME AND FLOOR THRESHOLD COMPLETE.
  - EXISTING GYPSUM BOARD SOFFIT TO REMAIN.
  - REMOVE AND REINSTALL BABY CHANGING STATION. REFER TO NEW FLOOR PLANS AND INTERIOR ELEVATIONS.



- ### GENERAL NOTES - DEMOLITION
- DASHED LINES INDICATE ITEMS TO BE REMOVED. REFER TO DEMOLITION NOTES FOR SPECIFIC INSTRUCTIONS.
  - REFER TO SHEET A2.0 FOR EXTENTS OF RENOVATION.
  - CONTRACTOR SHALL VERIFY EXISTING CONDITIONS AND SHALL NOTIFY THE ARCHITECT IMMEDIATELY OF ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS, AREAS OF DEMOLITION AND NEW WORK CONFIGURATIONS SHOWN IN THE CONSTRUCTION DRAWINGS.
  - INFORMATION REGARDING FIRE PROTECTION, MECHANICAL, PLUMBING AND ELECTRICAL TO BE REMOVED HAS BEEN INCLUDED FOR REFERENCE ONLY. REFER TO FIRE PROTECTION, MECHANICAL, PLUMBING AND ELECTRICAL CONSTRUCTION DOCUMENTS FOR COMPLETE INSTRUCTIONS ON THE REMOVAL OF THESE ITEMS.
  - EXISTING FIRE PROTECTION, MECHANICAL, PLUMBING, ELECTRICAL AND OTHER LIFE SAFETY SYSTEMS MUST CONTINUE TO OPERATE AS REQUIRED TO SATISFY THE OWNER AND GOVERNING REGULATIONS THROUGHOUT THE CONSTRUCTION PERIOD.
  - ALL MATERIALS, FIXTURES, CASEWORK, FURNITURE, EQUIPMENT AND OTHER ITEMS REMOVED FROM THE AREAS OF DEMOLITION ARE AND SHALL REMAIN THE PROPERTY OF THE OWNER UNLESS OTHERWISE STIPULATED BY THE OWNER OR ARCHITECT. ALL MATERIALS TO REMAIN SHALL BE REMOVED AND REMAIN IN ITS EXISTING STATE OF CONDITION. CONTRACTOR SHALL NOTIFY THE OWNER AND ARCHITECT IMMEDIATELY IF MATERIALS CANNOT BE REMOVED IN SAID EXISTING CONDITION STATE.
  - ALL ADJACENT SURFACES TO THE AREA OF DEMOLITION WHICH ARE SCHEDULED TO REMAIN AND ARE IN ANY MANNER AFFECTED BY THE WORK SHALL BE PATCHED TO MATCH AS STIPULATED BY THE OWNER OR ARCHITECT.
  - CONTRACTOR SHALL REMOVE PORTIONS OF EXISTING CONSTRUCTION AS REQUIRED FOR INSTALLATION OF NEW FIRE PROTECTION, MECHANICAL, PLUMBING, AND / OR ELECTRICAL ITEMS AS INDICATED ON THE CONSTRUCTION DOCUMENTS. ALL SURFACES AFFECTED SHALL BE PATCHED UPON COMPLETION OF THE NEW WORK AS REQUIRED TO MATCH ADJACENT FINISHED SURFACES.
  - NOISE, VIBRATION AND DUST LEVELS SHALL BE KEPT TO A MINIMUM TO AVOID DISTURBANCES TO ONGOING ACTIVITIES IN ADJACENT AREAS. CONTRACTOR SHALL MEET ALL OWNER REQUIREMENTS FOR WORK, DEMOLITION, WELDING, NOISE, ETC.
  - ALL LOCATIONS OF DUCTWORK AND PIPING REMOVAL THROUGH EXISTING WALL CONSTRUCTION SCHEDULED TO REMAIN SHALL BE PATCHED WITH MATERIALS IDENTICAL TO ADJACENT CONSTRUCTION AS REQUIRED FOR UNIFORM TRANSITIONS TO ADJACENT FINISHED SURFACES.
  - CONTRACTOR SHALL PROVIDE ALL TEMPORARY PARTITIONS, TEMPORARY DOOR, CEILING PROTECTION, ETC. TO SECURE PROJECT AREAS AT ALL TIMES, PROTECT CONSTRUCTION TO REMAIN AND AVOID MIGRATION OF DUST INTO ADJACENT OCCUPIED AREAS.
  - CUTTING OF EXISTING CONSTRUCTION SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR PERFORMING THE WORK FOR WHICH THE CUTTING IS REQUIRED. PATCHING SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR PERFORMING THE WORK FOR WHICH THE CUTTING AND PATCHING IS REQUIRED AND SHALL BE PERFORMED BY A PERSON(S) SKILLED IN THE TRADE INVOLVED.
  - ALL DEBRIS SHALL BE DISPOSED OF IN A MANNER ACCEPTABLE TO THE REGULATORY AUTHORITY HAVING JURISDICTION.
  - IF THE CONTRACTOR ENCOUNTERS ANY HAZARDOUS MATERIAL (ASBESTOS) THAT IS SUSPECTED, THE OWNER SHALL BE NOTIFIED IMMEDIATELY. THE OWNER SHALL BE RESPONSIBLE FOR ALL HAZARDOUS (ASBESTOS) REMOVAL.
  - ALL STRUCTURAL ELEMENTS (COLUMNS, BEAMS, ETC.) SHALL REMAIN DURING DEMOLITION AND NEW WORK. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING THESE ITEMS AND ALL FIRE PROTECTION, ACCESSORIES DURING THE PROJECT.
  - CONTRACTOR SHALL NOT "ABANDON IN PLACE" ANY PIPING, CONDUITS, ETC. (SEE MEP DRAWINGS).
  - CONTRACTOR SHALL PROVIDE NEGATIVE EXHAUST TO THE EXTERIOR.
  - STUDENT / STAFF PRIVACY AND CONFIDENTIALITY SHALL BE EXERCISED AT ALL TIMES.
  - ALL CONTRACTORS SHALL ABIDE BY OWNER'S PARKING AND ACCESS REQUIREMENTS FOR THE DURATION OF THE PROJECT.



CONSULTANTS

---



---



---



---



---

**SB840 WIEKAMP HALL - RESTROOM REMODEL**  
**INDIANA UNIVERSITY SOUTH BEND - IU#20222221**  
 1700 E Mishawaka Ave, South Bend, IN 46615  
**PARTIAL FIRST FLOOR DEMOLITION PLAN- NORTH RESTROOM**



### CONSTRUCTION DOCUMENTS


THIS PRINT IS THE PROPERTY OF HUTTON & HUTTON ARCHITECTS & ENGINEERS AND IS CONFIDENTIAL. IT IS NOT TRANSFERABLE AND IS FURNISHED WITH THE CLEAR UNDERSTANDING THAT IT IS NOT TO BE TRACED OR OTHERWISE REPRODUCED WITHOUT PERMISSION AND IS RETURNABLE UPON REQUEST.

NO.	DESCRIPTION	DATE
1	ADDENDUM-01	02/25/26

ISSUE DATE: **11/19/2025**  
 SHEET NO. **A1.1**  
 JOB NUMBER **IUSB2501**


**1** PARTIAL DEMOLITION FIRST FLOOR PLAN - SOUTH RESTROOM

3/8" = 1'-0"



**2** PARTIAL DEMOLITION FIRST FLOOR CEILING PLAN - SOUTH RESTROOM


3/8" = 1'-0"



**DEMOLITION NOTES**

- 1 EXISTING CONSTRUCTION TO REMAIN AND BE PROTECTED DURING CONSTRUCTION, THIS AREA.
- 2 EXISTING ACCESS PANEL (REFER TO COMPLETE DRAWINGS FOR ADDITIONAL INFORMATION).
- 3 REMOVE EXISTING CEILING ITEMS COMPLETE, THIS AREA. (REFER TO MEP DRAWINGS FOR ADDITIONAL INFORMATION).
- 4 REMOVE EXISTING GYPSUM BOARD CEILING / SOFFIT, COMPLETE THIS AREA AS REQUIRED FOR NEW CONSTRUCTION.
- 5 REMOVE EXISTING WALL FINISH AND WALL BASE COMPLETE THIS AREA. PREPARE REMAINING SURFACES AS REQUIRED FOR APPLICATION OF NEW FINISHES. (REFER TO FINISH DRAWINGS)
- 6 REMOVE AND DISPOSE OF EXISTING PLUMBING FIXTURES AND EXISTING TOILET ACCESSORIES COMPLETE. REPAIR ALL WALL PENETRATIONS AS REQUIRED. (REFER TO PLUMBING DRAWINGS).
- 7 REMOVE TOILET PARTITIONS AND STRUCTURAL SUPPORTS ABOVE IN ENTIRETY. STRUCTURAL COMPONENTS MAY REMAIN AS LONG AS THEY DO NOT IMPERE ANY NEW / EXISTING WORK. CONTRACTOR SHALL INCLUDE COST OF STRUCTURAL REMOVAL. NOTIFY ARCHITECT / OWNER DURING CONSTRUCTION OF INTENT TO REMOVE OR STAY PRIOR TO WORK.
- 8 REMOVE EXISTING FINISH FLOORING AND BASE COMPLETE THIS AREA. PREPARE REMAINING SURFACES AS REQUIRED FOR APPLICATION OF NEW FINISHES.
- 9 REMOVE AND DISPOSE OF EXISTING WALL MOUNTED AND RECESSED IN WALL CORNER GUARDS, HAND RAILS, TOILET ACCESSORIES, ETC. COMPLETE THIS AREA ON ALL WALLS INDICATED TO REMAIN AND SHIM COAT ALL AFFECTED SURFACES AS REQUIRED AND PREPARE SURFACES FOR APPLICATION OF NEW WALL FINISHES.
- 10 EXISTING FLOOR DRAIN TO REMAIN. REMOVE EXISTING DRAIN COVER. (REFER TO PLUMBING DRAWINGS FOR ADDITIONAL INFORMATION).
- 11 REMOVE AND DISPOSE OF EXISTING PLUMBING FIXTURE FOR INSTALLATION OF NEW FIXTURES. REPAIR ALL WALL PENETRATIONS TO MATCH EXISTING ADJACENT WALL SURFACES AND PREPARE SURFACES FOR APPLICATION OF NEW WALL FINISHES.
- 12 REMOVE EXISTING WALL TILE AND GYPSUM BOARD LAYERS COMPLETE TO METAL STUDS. DRAWINGS ASSUME NEW LAYER OF CEMENT BOARD AND / OR GYPSUM BOARD AND WALL TILE. (SEE A0.2 FOR PARTITION DETAILS).
- 13 REMOVE AND DISPOSE OF EXISTING DOORWAY FRAME AND FLOOR THRESHOLD COMPLETE.
- 14 EXISTING GYPSUM BOARD SOFFIT TO REMAIN.
- 15 REMOVE AND REINSTALL BABY CHANGING STATION. REFER TO NEW FLOOR PLANS AND INTERIOR ELEVATIONS.

**DEMOLITION LEGEND**



**GENERAL NOTES - DEMOLITION**

1. DASHED LINES INDICATE ITEMS TO BE REMOVED. REFER TO DEMOLITION NOTES FOR SPECIFIC INSTRUCTIONS.
2. REFER TO SHEET A2.0 FOR EXTENTS OF RENOVATION.
3. CONTRACTOR SHALL VERIFY EXISTING CONDITIONS AND SHALL NOTIFY THE ARCHITECT IMMEDIATELY OF ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS, AREAS OF DEMOLITION AND NEW WORK CONFIGURATIONS SHOWN IN THE CONSTRUCTION DRAWINGS.
4. INFORMATION REGARDING FIRE PROTECTION, MECHANICAL, PLUMBING AND ELECTRICAL TO BE REMOVED HAS BEEN INCLUDED FOR REFERENCE ONLY. REFER TO FIRE PROTECTION, MECHANICAL, PLUMBING AND ELECTRICAL CONSTRUCTION DOCUMENTS FOR COMPLETE INSTRUCTIONS ON THE REMOVAL OF THESE ITEMS.
5. EXISTING FIRE PROTECTION, MECHANICAL, PLUMBING, ELECTRICAL AND OTHER LIFE SAFETY SYSTEMS MUST CONTINUE TO OPERATE AS REQUIRED TO SATISFY THE OWNER AND GOVERNING REGULATIONS THROUGHOUT THE CONSTRUCTION PERIOD.
6. ALL MATERIALS, FIXTURES, CASEWORK, FURNITURE, EQUIPMENT AND OTHER ITEMS REMOVED FROM THE AREAS OF DEMOLITION ARE AND SHALL REMAIN THE PROPERTY OF THE OWNER UNLESS OTHERWISE STIPULATED BY THE OWNER OR ARCHITECT. ALL MATERIALS TO REMAIN SHALL BE REMOVED AND REMAIN IN ITS EXISTING STATE OF CONDITION. CONTRACTOR SHALL NOTIFY THE OWNER AND ARCHITECT IMMEDIATELY IF MATERIALS CANNOT BE REMOVED IN SAID EXISTING CONDITION STATE.
7. ALL ADJACENT SURFACES TO THE AREA OF DEMOLITION WHICH ARE SCHEDULED TO REMAIN AND ARE IN ANY MANNER AFFECTED BY THE WORK SHALL BE PATCHED TO MATCH AS STIPULATED BY THE OWNER OR ARCHITECT.
8. CONTRACTOR SHALL REMOVE PORTIONS OF EXISTING CONSTRUCTION AS REQUIRED FOR INSTALLATION OF NEW FIRE PROTECTION, MECHANICAL, PLUMBING, AND / OR ELECTRICAL ITEMS AS INDICATED ON THE CONSTRUCTION DOCUMENTS. ALL SURFACES AFFECTED SHALL BE PATCHED UPON COMPLETION OF THE NEW WORK AS REQUIRED TO MATCH ADJACENT FINISHED SURFACES.
9. NOISE, VIBRATION AND DUST LEVELS SHALL BE KEPT TO A MINIMUM TO AVOID DISTURBANCES TO ONGOING ACTIVITIES IN ADJACENT AREAS. CONTRACTOR SHALL MEET ALL OWNER REQUIREMENTS FOR WORK, DEMOLITION, WELDING, NOISE, ETC.
10. ALL LOCATIONS OF DUCTWORK AND PIPING REMOVAL THROUGH EXISTING WALL CONSTRUCTION SCHEDULED TO REMAIN SHALL BE PATCHED WITH MATERIALS IDENTICAL TO ADJACENT CONSTRUCTION AS REQUIRED FOR UNIFORM TRANSITIONS TO ADJACENT FINISHED SURFACES.
11. CONTRACTOR SHALL PROVIDE ALL TEMPORARY PARTITIONS, TEMPORARY DOOR, CEILING PROTECTION, ETC. TO SECURE PROJECT AREAS AT ALL TIMES, PROTECT CONSTRUCTION TO REMAIN AND AVOID MIGRATION OF DUST INTO ADJACENT OCCUPIED AREAS.
12. CUTTING OF EXISTING CONSTRUCTION SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR PERFORMING THE WORK FOR WHICH THE CUTTING IS REQUIRED. PATCHING SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR PERFORMING THE WORK FOR WHICH THE CUTTING AND PATCHING IS REQUIRED AND SHALL BE PERFORMED BY A PERSON(S) SKILLED IN THE TRADE INVOLVED.
13. ALL DEBRIS SHALL BE DISPOSED OF IN A MANNER ACCEPTABLE TO THE REGULATORY AUTHORITY HAVING JURISDICTION.
14. IF THE CONTRACTOR ENCOUNTERS ANY HAZARDOUS MATERIAL (ASBESTOS) THAT IS SUSPECTED, THE OWNER SHALL BE NOTIFIED IMMEDIATELY. THE OWNER SHALL BE RESPONSIBLE FOR ALL HAZARDOUS (ASBESTOS) REMOVAL.
15. ALL STRUCTURAL ELEMENTS (COLUMNS, BEAMS, ETC.) SHALL REMAIN DURING DEMOLITION AND NEW WORK. THE CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTING THESE ITEMS AND ALL FIRE PROTECTION, ACCESSORIES DURING THE PROJECT.
16. CONTRACTOR SHALL NOT "ABANDON IN PLACE" ANY PIPING, CONDUITS, ETC. (SEE MEP DRAWINGS).
17. CONTRACTOR SHALL PROVIDE NEGATIVE EXHAUST TO THE EXTERIOR.
18. STUDENT / STAFF PRIVACY AND CONFIDENTIALITY SHALL BE EXERCISED AT ALL TIMES.
19. ALL CONTRACTORS SHALL ABIDE BY OWNER'S PARKING AND ACCESS REQUIREMENTS FOR THE DURATION OF THE PROJECT.

**KEYPLAN**



**CONSULTANTS**



**SB840 WIEKAMP HALL - RESTROOM REMODEL**  
**INDIANA UNIVERSITY SOUTH BEND - IU#20222221**  
 1700 E Mishawaka Ave, South Bend, IN 46615  
**PARTIAL FIRST FLOOR DEMOLITION PLAN - SOUTH RESTROOM**



**CONSTRUCTION DOCUMENTS**

THIS PRINT IS THE PROPERTY OF HUTTON & HUTTON ARCHITECTS & ENGINEERS AND IS CONFIDENTIAL. IT IS NOT TRANSFERABLE AND IS FURNISHED WITH THE CLEAR UNDERSTANDING THAT IT IS NOT TO BE TRACED OR OTHERWISE REPRODUCED WITHOUT PERMISSION AND IS RETURNABLE UPON REQUEST.

NO.	DESCRIPTION	DATE
1	ADDENDUM-01	02/25/26

ISSUE DATE: **11/19/2025**  
 SHEET NO. **A1.2**  
 JOB NUMBER **IUSB2501**





Hutton & Hutton Architects & Engineers  
6832 Calumet Ave. Hammond, IN, 46324  
(219) 932-2050 HHAES.com

CONSULTANTS



**SB840 WIEKAMP HALL - RESTROOM REMODEL**  
INDIANA UNIVERSITY SOUTH BEND - IU#20222221  
1700 E Mishawaka Ave, South Bend, IN 46615  
INTERIOR ELEVATIONS



CONSTRUCTION DOCUMENTS

THIS PRINT IS THE PROPERTY OF HUTTON & HUTTON ARCHITECTS & ENGINEERS AND IS CONFIDENTIAL. IT IS NOT TRANSFERABLE AND IS FURNISHED WITH THE CLEAR UNDERSTANDING THAT IT IS NOT TO BE TRACED OR OTHERWISE REPRODUCED WITHOUT PERMISSION AND IS RETURNABLE UPON REQUEST.

NO.	DESCRIPTION	DATE
1	ADDENDUM-01	02/25/26

ISSUE DATE: 11/19/2025

SHEET NO.

**A4.0**

JOB NUMBER  
**IUSB2501**

GENERAL NOTES - INTERIOR ELEVATION

- CONTRACTOR SHALL VERIFY EXISTING PROJECT SITE CONDITIONS AND SHALL NOTIFY THE ARCHITECT IMMEDIATELY OF ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS AND CONFIGURATIONS SHOWN IN THE CONSTRUCTION DOCUMENTS.
- REFERENCE MECHANICAL, PLUMBING AND ELECTRICAL DOCUMENTS FOR DELINEATION OF ALL WORK WITHIN THEIR RESPECTIVE PORTIONS OF WORK.
- WHERE DIMENSIONS ARE NOT SPECIFICALLY INDICATED FOR POWER AND SYSTEMS OUTLETS, ALIGN OUTLETS HORIZONTALLY ON CENTERLINE OF SURROUNDING MODULAR CASEWORK AS SHOWN ON INTERIOR ELEVATIONS.
- CONTRACTOR SHALL VERIFY FINAL CONFIGURATION OF ALL EQUIPMENT, INCLUDING CONTRACTOR FURNISHED STRUCTURAL, ARCHITECTURAL, MECHANICAL, PLUMBING AND ELECTRICAL ITEMS ASSOCIATED WITH EQUIPMENT. VERIFY WITH THE OWNER AND ARCHITECT PRIOR TO COMMENCEMENT OF WORK RELATED TO THESE ITEMS.
- ALL DIMENSIONS ARE FROM FINISH FACE OF WALL TO FINISH FACE OF WALL UNLESS NOTED OTHERWISE.
- ALL CASEWORK SHALL BE FABRICATED IN ACCORDANCE WITH ALL APPLICABLE PROVISIONS OF THE AMERICANS WITH DISABILITIES ACT (ADA) INCLUDING REQUIRED 27" KNEESPACE CLEARANCES.
- ALL CASEWORK SHALL BE FABRICATED IN ACCORDANCE WITH ALL APPLICABLE PROVISIONS OF THE MOST CURRENT EDITION OF THE ARCHITECTURAL WOODWORK INSTITUTE (AWI) QUALITY STANDARDS.
- REFERENCE TOILETS AND BATH ACCESSORIES SPECIFICATION SECTION (DIVISION 10) FOR TOILET ACCESSORY ITEMS AND SCHEDULE.
- ALL CASEWORK CABINETS / DRAWERS / DOORS / ETC. AND TOILET PARTITIONS SHALL HAVE DOOR STOPS OR SILENCERS TO PREVENT THE DIRECT COLLISION WITH ANY ADJACENT SURFACE. CONTRACTOR SHALL SUBMIT TO ARCHITECT FOR APPROVAL PRIOR TO FINAL INSTALLATION.

INTERIOR ELEVATION NOTES


- INTEGRAL SINK WITH DYSON AIRBLADE TAP WASH & DRY SHORT HAND DRYER (REFER TO MEP DRAWINGS FOR ADDITIONAL PLUMBING AND ELECTRICAL INFORMATION). PROVIDE ELECTRICAL POWER AS MANUFACTURER REQUIRES. CONTRACTOR SHALL BE RESPONSIBLE FOR ANY ADDITIONAL REINFORCEMENT REQUIRED FOR COMPLETE INSTALLATION.
- SOLID SURFACE COUNTERTOP WITH APRON, EASED EDGES, INTEGRAL BACKSPLASH AND SIDE SPLASHES WITH CONTINUOUS SEALANT. REFER TO SECTION DETAIL (AS.0) AND FINISH SCHEDULE (F.O.0).
- DYSON MOTOR BUCKET. (REFER TO MEP DRAWINGS FOR ADDITIONAL PLUMBING AND ELECTRICAL INFORMATION).
- REMOVABLE DECORATIVE LAMINATE CLAD ANGLED PANEL WITH STAINLESS STEEL DRESS SCREWS. PROVIDE IN SECTIONS FOR ACCESS TO EACH SINK.
- 3/4" THICK DECORATIVE LAMINATE END PANEL TO MATCH PROFILE OF ANGLED PANEL, FLUSH WITH COUNTERTOP ABOVE. REFER TO CASEWORK SECTION DETAIL (AS.0).
- WALL BASE (BT1). REFER TO FINISH DRAWINGS.
- WALL BASE (VB1). REFER TO FINISH DRAWINGS.
- WALL TILE (WT1). REFER TO FINISH DRAWINGS.
- WALL TILE (WT2). REFER TO FINISH DRAWINGS.
- CORNER GUARD (CG2). REFER TO FINISH SCHEDULE (F.O.0).
- PLUMBING FIXTURE. REFER TO PLUMBING DRAWINGS.
- GYPSUM BOARD, PAINTED. REFER TO FINISH DRAWINGS.
- EXISTING CONSTRUCTION TO REMAIN.
- DOOR ACTUATOR. REFER TO ELECTRICAL DRAWINGS AND HARDWARE SPECIFICATIONS.
- 8 1/2" X 11" ACRYLIC PANEL MOUNTED TO BACKSIDE OF THE DOOR (D.F.O.I.). COORDINATE WITH ROBE HOOK TA-11.
- NEW DRINKING FOUNTAINS / WATER BOTTLE FILLING STATIONS AND INSTALLED AS PER SPECIFICATIONS. REFER TO EQUIPMENT SPECIFICATIONS AND MEP DRAWINGS.
- 1" TOILET PARTITION. REFER TO FINISH SCHEDULE (F.O.0) AND SPECIFICATIONS.
- 1" URINAL WALL - MOUNTED PARTITION. REFER TO SPECIFICATIONS.
- REFER TO FIXTURE'S MANUFACTURER'S RECOMMENDATION FOR OUTLET LOCATION.
- CORNER GUARD (CG1). REFER TO FINISH SCHEDULE (F.O.0).
- EXISTING SOFFIT TO REMAIN.

TOILET LEGEND


ACCESSORIES

Item	Description	Manufacturer/Product Number	Mounting
TA-01	36" Grab Bar	Bobrick B-6806 x 36	35" AFF/CL
TA-02	42" Grab Bar	Bobrick B-6806 x 42	35" AFF/CL
TA-03	18" Grab Bar - Vertical	Bobrick B-6806 x 18	40" AFF/CL
TA-04	24" x 36" Mirror	Bobrick B-2008 x 2436	40" AFF/BT
TA-05	Toilet Paper Dispenser	Owner Furnished, Contractor Installed	19" AFF/DS
TA-06	Soap Dispenser	Owner Furnished, Contractor Installed	44" AFF/DS
TA-07	Full Length Mirror	Bobrick B-290 x 2460	16" AFF/BT
TA-08	Baby Changing Station	Bobrick KB-200 SS	35" AFF/78
TA-09	Sanitary Napkin Disposal	Bobrick B-270 (Surface Mounted)	15" AFF/BT
TA-10	Seal Cover Dispenser (Surface Mounted)	Bobrick B-4221	35" AFF/BT
TA-11	Robe Hook	Refer to Section 10 21 13	CWA
TA-11A	Robe Hook	Bobrick B-682	CWA
TA-12	Waste Receptacle	Owner Furnished, Owner Installed	44" AFF/DS
TA-13	Paper Towel Dispenser	Owner Furnished, Owner Installed (Not More than 4" Extension in Accessible Path)	
TA-14	Hand Dryer (In Faucet)	Refer to Plumbing Documents	


Mounting Abbreviations: TP = top, CL = centerline, BT = bottom, DS = centerline of dispensing mechanism, TB = top of bed, SB = start button, CWA = coordinate with Architect.




14 CORRIDOR 1099 - WATER BOTTLE FILLING STATION - WEST  
IE  
1/2" = 1'-0"




13 ALCOVE AT CORRIDOR 1299E - SOUTH  
IE  
1/2" = 1'-0"




12 AMBULATORY ACCESSIBLE COMPARTMENT - SIDE  
IE  
1/2" = 1'-0"




11 AMBULATORY ACCESSIBLE COMPARTMENT - SIDE  
IE  
1/2" = 1'-0"




10 GENDER NEUTRAL RESTROOM - 1204A - EAST  
IE  
1/2" = 1'-0"




9 GENDER NEUTRAL RESTROOM - 1204A - NORTH  
IE  
1/2" = 1'-0"




8 GENDER NEUTRAL RESTROOM - 1204A - WEST  
IE  
1/2" = 1'-0"




7 GENDER NEUTRAL RESTROOM - 1230A - WEST  
IE  
1/2" = 1'-0"




6 GENDER NEUTRAL RESTROOM - 1230A - EAST  
IE  
1/2" = 1'-0"




5 WOMEN'S RESTROOM - 1230 - WEST  
IE  
1/2" = 1'-0"




4 WOMEN'S RESTROOM - 1230 - EAST  
IE  
1/2" = 1'-0"









3 WOMEN'S RESTROOM - 1230 - SOUTH  
IE  
1/2" = 1'-0"



2 MEN'S RESTROOM - 1204 - WEST  
IE  
1/2" = 1'-0"



1 MEN'S RESTROOM - 1204 - EAST  
IE  
1/2" = 1'-0"



### FINISH SCHEDULE

FLOOR FINISHES (F)							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
FT1	COLORBODY PORCELAIN CUSTOM 2\"/>						
FT2	COLORBODY PORCELAIN 2\"/>						
GR1	FLOOR TILE GROUT	MAPEI	SANDED	CHARCOAL 47	-	09 31 00	FLOOR TILE GROUT, BOTH FT1 & FT2
VCT1	VINYL COMPOSITION TILE	ARMSTRONG	STANDARD EXCELON/IMPERIAL TEXTURE (TO MATCH EXISTING)	-	12\"/>		
NC	EXISTING FLOOR TO REMAIN	-	-	-	-	-	EXISTING FLOOR TO REMAIN; REPAIR AS NEEDED, THIS AREA

BASE FINISHES (B)							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
VB1	VINYL BASE	JOHNSONITE / TARKETT	TRADITIONAL (MATCH EXISTING)	-	4\"/>		
BT1	GLAZED CERAMIC BASE TILE	AMERICAN OLEAN	"COLOR STORY WALL" FLAT TOP COVE BASE	A3601 "ICE WHITE 0025" (GLOSS)	6\"/>		
BT1	GLAZED CERAMIC BASE TILE	AMERICAN OLEAN	"COLOR STORY WALL" SANITARY COVE BASE	S3619T "ICE WHITE 0025" (GLOSS)	6\"/>		
GR2	GROUT	MAPEI	UNSANDED	BISCUIT 14	-	09 31 00	GLAZED CERAMIC BASE & WALL TILE GROUT FOR USE WITH WT1 & BT1
NC	EXISTING BASE TO REMAIN	-	-	-	-	09 65 00	EXISTING BASE TO REMAIN

WALL FINISHES (W)							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
PT1	PAINT	SHERWIN WILLIAMS	EGGSHELL	SW7064 - PASSIVE	-	09 90 00	TO MATCH EXISTING CORRIDORS. NOTIFY ARCHITECT IF EXISTING COLOR DOES NOT MATCH THIS.
PT2	PAINT	SHERWIN WILLIAMS	EGGSHELL	SW7647 - CRUSHED ICE	-	09 90 00	FOR DRYWALL ABOVE WALL TILE IN TOILET ROOMS
PT4	PAINT	SHERWIN WILLIAMS EMERALD DESIGNER EDITION	-	SW9557 - MATTE AUTONIMOUS	-	-	TO MATCH EXISTING CORRIDORS. NOTIFY ARCHITECT IF EXISTING COLOR DOES NOT MATCH THIS.
PT5	PAINT	SHERWIN WILLIAMS EMERALD DESIGNER EDITION	-	SW9561 - MATTE GUILD GREY	-	-	TO MATCH EXISTING CORRIDORS. NOTIFY ARCHITECT IF EXISTING COLOR DOES NOT MATCH THIS.
WT1	GLAZED CERAMIC WALL TILE	AMERICAN OLEAN	"COLOR STORY WALL" 3\"/>				
WT2	PORCELAIN WALL TILE	MARAZZI	ILLUSIONIST COLORBODY PORCELAIN	IL50 MAGICAL (WALL TILE) - IL48 SMOKE (WALL BASE)	WALL TILE: 1 X 24 MOSAIC, VERTICAL, 12X24 SHEET - WALL BASE: 6X24 FLOOR TILE, HORIZONTAL	09 31 13	USED AT TWO PAIRED DRINKING FOUNTAIN AREAS ONLY. IL50 MAGICAL INSTALLED VERTICALLY WITH 1/8\"/>
GR2	GROUT	MAPEI	UNSANDED	BISCUIT 14	-	09 31 00	GLAZED CERAMIC WALL & BASE TILE GROUT FOR USE WITH WT1 & BT1
GR3	GROUT	MAPEI	UNSANDED	AVALANCHE - 38	-	09 31 00	GLAZED CERAMIC WALL TILE GROUT FOR USE WITH WT2 ONLY
NC	EXISTING WALL FINISHES TO REMAIN	-	-	-	-	-	EXISTING WALL FINISHES TO REMAIN

CEILING FINISHES (C)							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
ACT1	ACOUSTICAL CEILING TILE	ARMSTRONG	TUNDRA 303 TEGULAR	COLOR WHITE	24\"/>		
ACT-A	ACOUSTICAL CEILING GRID	ARMSTRONG	5/16 PRELUDE	WHITE	-	09 51 00	CONTRACTOR MAY PROVIDE AS EQUAL PRODUCT CERTAINTEEED GRID
PT6	GYPSON BOARD CEILING PAINT	SHERWIN WILLIAMS EMERALD DESIGNER EDITION	-	SW7006 - MATTE EXTRA WHITE	-	09 51 00	TO MATCH EXISTING CORRIDORS. NOTIFY ARCHITECT IF EXISTING COLOR DOES NOT MATCH THIS.
NC	EXISTING WALL FINISHES TO REMAIN	-	-	-	-	-	EXISTING WALL FINISHES TO REMAIN

DOOR/ FRAME/ TRIM FINISHES							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
PT3	PAINT	SHERWIN WILLIAMS	SEMI-GLOSS	-	-	06 40 00	CONTRACTOR SHALL SUBMIT COLOR TO ARCHITECT FOR APPROVAL PRIOR TO DRAWDOWN SUBMISSION
WOOD DOOR	STAINED	SEE SPECIFICATIONS	SEE SPECIFICATIONS	-	-	09 93 00, 08 14 00	CONTRACTOR SHALL SUBMIT FOR APPROVAL STAIN SAMPLES ON WOOD SPECIES THAT MATCH EXISTING STAINED DOORS

CASEWORK FINISHES							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
SS1	COUNTERTOP	STARON	SOLID SURFACE	STARON "TEMPEST" (HORIZON FH14)	-	06 40 00	CONTRACTOR MAY PROVIDE AS EQUAL PRODUCT LIVINGSTONE AVALANCHE L721 OR OTHER APPROVED EQUAL PRODUCT. CASEWORK LAMINATE BELOW SOLID SURFACE COUNTERTOP SHALL BE COLOR "PEARL 934-58" BY FORMICA. (SEE PL1 BELOW)
SS2	SINK	-	SOLID SURFACE	B110 OD: 18 1/2\"/>			
PL-1	CASEWORK PLASTIC LAMINATE	FORMICA	MATTE FINISH	PEARL 934-58	-	06 41 16	-

WALL PROTECTION							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
CG1	CERAMIC TILE CORNER TRIM	SCHLUTER SYSTEMS	QUADEC	SATIN ANODIZED ALUMINUM	4\"/>		
CG2	GYPSON WALL CORNER GUARD	INPRO, WALLGUARD OR APPROVED EQUAL	2\"/>				
TRIM	TOP ROW CERAMIC WALL TILE TO GYPSON BOARD TRANSITION STRIP	PITTCO SOFTFORMS	1/4\"/>				

MISCELLANEOUS							
ABBREVIATION	TYPE	MANUFACTURER	SERIES	PRODUCT #	INSTALL/ PATTERN	SPEC SECTION	REMARKS
-	TOILET PARTITIONS	GLOBAL PARTITIONS	DIAMOND TEXTURED STAINLESS STEEL	SSM	PER DRAWINGS AND SPECIFICATIONS	10 21 13	FLOOR MOUNTED, OVERHEAD BRACED

### GENERAL NOTES - FINISH

- CONTRACTOR SHALL VERIFY EXISTING PROJECT SITE CONDITIONS AND SHALL NOTIFY THE ARCHITECT IMMEDIATELY OF ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS AND CONFIGURATIONS SHOWN IN THE CONSTRUCTION DOCUMENTS.
- PROVIDE ADA COMPLIANT TRANSITION/THRESHOLD ELEMENTS AS REQUIRED AT ALL INTERSECTIONS OF DIFFERENT FLOOR FINISHES AND DOOR OPENINGS. ALL TRANSITIONS IN FLOOR FINISHES SHALL OCCUR UNDER CENTERLINE OF DOORS.
- COORDINATE PAINTING OF ALL VERTICAL AND HORIZONTAL FACES OF SOFFITS WITH ARCHITECT.
- INDICATES THE GRAIN DIRECTION OF VINYL PLANK FLOORING. LINEAR PATTERN DIRECTION OF CARPET, AND LONG AXIS OF PORCELAIN TILE.
- ALL DIMENSIONS ARE FROM FINISH FACE OF WALL TO FINISH FACE OF WALL UNLESS NOTED OTHERWISE.
- SEALANT SHALL BE PROVIDED AT ALL INTERSECTIONS OF DISSIMILAR MATERIALS AS REQUIRED FOR WEATHER RESISTANCE AND/OR PAINTING.
- ALL ADJACENT SURFACES TO THE AREAS OF DEMOLITION WHICH ARE SCHEDULED TO REMAIN AND ARE IN ANY MANNER AFFECTED BY THE WORK SHALL BE PATCHED AS REQUIRED TO MATCH THE ADJACENT FINISHED SURFACE.
- ARCHITECT SHALL PROVIDE ELECTRONIC FLOOR PLAN FOR FLOOR PATTERN USE TO THE CONTRACTOR UPON DIGITAL FILE REQUEST TO ASSIST IN LAYOUT OF ALL FLOORING.
- COUNTERTOPS SHALL BE SEAMLESS UNLESS NOTED OTHERWISE. CONTRACTOR SHALL SUBMIT ANY REQUIRED SEAMS TO THE ARCHITECT FOR APPROVAL PRIOR TO FABRICATION AND INSTALLATION; ALL APPROVED SEAMS SHALL BE FLUSH / TIGHT AND SEALED, NO CHIPPING, GAPS, ETC. WILL BE ALLOWED.
- CONTRACTOR IS RESPONSIBLE FOR FLOATING / GRINDING / LEVELING THE EXISTING FLOOR AS REQUIRED FOR ALL NEW WORK FOR FLUSH FLOOR TRANSITIONS. NEW MATERIAL INSTALLATIONS ON LEVEL SURFACE AS REQUIRED. CONTRACTOR SHALL NOTIFY ARCHITECT OF ANY AREAS PRIOR TO WORK BEING COMPLETED.

### FINISH ABBREVIATIONS

- ACT ACOUSTICAL CEILING TILE
- B BASE
- C CEILING
- CG CORNER GUARD
- CTP CARPET
- CT CERAMIC TILE
- EP EPOXY PAINT
- F FLOOR
- GCT GLAZED CERAMIC TILE
- GTP GLAZED TILE PANEL
- LAM HIGH PRESSURE LAMINATE
- L LINDSEUM
- MCT MATTE CERAMIC TILE
- NP NOT PAINTED
- PLA PLASTER
- PT PAINTED
- QT QUARRY TILE
- RB RESILIENT WALL BASE
- SCWD SOLID CORE WOOD DOOR
- SGT STRUCTURAL GLAZED TILE SHEET
- SVF SHEET VINYL FLOORING
- V VINYL
- VCT VINYL COMPOSITION TILE
- VCGB VINYL COVERED GYPSON BOARD
- VWFF VINYL WALL FABRIC
- VWFB VINYL WALL FABRIC BORDER
- VWFB/VINYL WALL FABRIC WITH BORDER
- W WALL
- WD WOOD



### CONSULTANTS



**SB840 WIEKAMP HALL - RESTROOM REMODEL**  
**INDIANA UNIVERSITY SOUTH BEND - IU#20222221**  
**1700 E Mishawaka Ave, South Bend, IN 46615**  
**FINISH SCHEDULE AND DETAILS**



### FINISH PLAN LEGEND

- (1) FINISH NOTE
- (F) FLOOR FINISH
- (B) WALL BASE
- (W) WALL FINISH
- (C) CEILING FINISH
- ROOM FINISH TAG
- ROOM NAME/ ROOM NUMBER
- ELEVATION TAG
- WALL ACCENT TAG
- FINISH FLOOR TAG
- CORNER GUARD


### CONSTRUCTION DOCUMENTS

THIS PRINT IS THE PROPERTY OF HUTTON & HUTTON ARCHITECTS & ENGINEERS AND IS CONFIDENTIAL. IT IS NOT TRANSFERABLE AND IS FURNISHED WITH THE CLEAR UNDERSTANDING THAT IT IS NOT TO BE TRACED OR OTHERWISE REPRODUCED WITHOUT PERMISSION AND IS RETURNABLE UPON REQUEST.


NO.	DESCRIPTION	DATE
1	ADDENDUM-01	02/25/26

ISSUE DATE: **11/19/2025**


SHEET NO.  
**F0.0**  
 FOR NUMBER  
**IUSB2501**




**2** PARTIAL FIRST FLOOR FINISH PLAN - SOUTH RESTROOM  
3/8" = 1'-0"




**1** PARTIAL FIRST FLOOR FINISH PLAN - NORTH RESTROOM  
3/8" = 1'-0"




**FINISHES - MOSAIC PATTERN SHEET FOR FT1**  
(FIELD TILE, FILE No. FROM DAL TILE)



**FINISHES - MOSAIC PATTERN SHEET FOR FT2**  
(BORDER TILE)



**FT1 PATTERN SHEET - ORIENTATION**  
(FOR PLAN LAYOUT)



**TYPICAL PLAN LAYOUT - FT1 & FT2**  
(SEE FLOOR PLAN FOR LOCATIONS)

**GENERAL NOTES - FINISH**

- CONTRACTOR SHALL VERIFY EXISTING PROJECT SITE CONDITIONS AND SHALL NOTIFY THE ARCHITECT IMMEDIATELY OF ANY DISCREPANCIES BETWEEN EXISTING CONDITIONS AND CONFIGURATIONS SHOWN IN THE CONSTRUCTION DOCUMENTS.
- PROVIDE ADA COMPLIANT TRANSITION/THRESHOLD ELEMENTS AS REQUIRED AT ALL INTERSECTIONS OF DIFFERENT FLOOR FINISHES AND DOOR OPENINGS. ALL TRANSITIONS IN FLOOR FINISHES SHALL OCCUR UNDER CENTERLINE OF DOORS.
- COORDINATE PAINTING OF ALL VERTICAL AND HORIZONTAL FACES OF SOFFITS WITH ARCHITECT.
- INDICATES THE GRAIN DIRECTION OF VINYL PLANK FLOORING. LINEAR PATTERN DIRECTION OF CARPET, AND LONG AXIS OF PORCELAIN TILE.
- ALL DIMENSIONS ARE FROM FINISH FACE OF WALL TO FINISH FACE OF WALL UNLESS NOTED OTHERWISE.
- SEALANT SHALL BE PROVIDED AT ALL INTERSECTIONS OF DISSIMILAR MATERIALS AS REQUIRED FOR WEATHER RESISTANCE AND/OR PAINTING.
- ALL ADJACENT SURFACES TO THE AREAS OF DEMOLITION WHICH ARE SCHEDULED TO REMAIN AND ARE IN ANY MANNER AFFECTED BY THE WORK SHALL BE PATCHED AS REQUIRED TO MATCH THE ADJACENT FINISHED SURFACE.
- ARCHITECT SHALL PROVIDE ELECTRONIC FLOOR PLAN FOR FLOOR PATTERN USE TO THE CONTRACTOR UPON DIGITAL FILE REQUEST TO ASSIST IN LAYOUT OF ALL FLOORING.
- COUNTERTOPS SHALL BE SEAMLESS UNLESS NOTED OTHERWISE. CONTRACTOR SHALL SUBMIT ANY REQUIRED SEAMS TO THE ARCHITECT FOR APPROVAL PRIOR TO FABRICATION AND INSTALLATION; ALL APPROVED SEAMS SHALL BE FLUSH / TIGHT AND SEALED, NO CHIPPING, GAPS, ETC. WILL BE ALLOWED.
- CONTRACTOR IS RESPONSIBLE FOR FLOATING / GRINDING / LEVELING THE EXISTING FLOOR AS REQUIRED FOR ALL NEW WORK FOR FLUSH FLOOR TRANSITIONS. NEW MATERIAL INSTALLATIONS ON LEVEL SURFACE AS REQUIRED. CONTRACTOR SHALL NOTIFY ARCHITECT OF ANY AREAS PRIOR TO WORK BEING COMPLETED.


**FINISH NOTES**

- SOLID SURFACE COUNTERTOP (SS1) WITH EASED EDGES AND INTEGRAL SINK (SS2).
- INTEGRAL SOLID SURFACE BACKSPLASH.
- SCHLUTER RENO-U FLOORING TRANSITION PROFILE.
- EXISTING FINISHES TO REMAIN.
- EXISTING FLOOR AND SOFFIT FINISHES TO REMAIN.
- TOP OF TILE CORNER TRIM(CG1) TO BUTT-JOINT BOTTOM OF GYPSUM BOARD ABOVE.
- ROOM SIGNAGE PER I.U. REQUIREMENTS. (TYPICAL, REFER TO OWNER SECTION 10 40 00)

**FINISH PLAN LEGEND**

(L)	FINISH NOTE	(F B W C)	FLOOR FINISH WALL BASE WALL FINISH CEILING FINISH	(R)	ROOM FINISH TAG
XXX XX	ROOM NAME/ ROOM NUMBER	(1 2 3 4 5 6 7)	ELEVATION TAG	(---)	WALL ACCENT TAG
(---)	WALL ACCENT TAG	(---)	FINISH FLOOR TAG	(---)	CORNER GUARD

**KEYPLAN**



**CONSULTANTS**


**SB840 WIEKAMP HALL - RESTROOM REMODEL**  
INDIANA UNIVERSITY SOUTH BEND - IU#20222221  
1700 E Mishawaka Ave, South Bend, IN 46615  
PARTIAL FIRST FLOOR FINISH PLANS



**CONSTRUCTION DOCUMENTS**

THIS PRINT IS THE PROPERTY OF HUTTON & HUTTON ARCHITECTS & ENGINEERS AND IS CONFIDENTIAL. IT IS NOT TRANSFERABLE AND IS FURNISHED WITH THE CLEAR UNDERSTANDING THAT IT IS NOT TO BE TRACED OR OTHERWISE REPRODUCED WITHOUT PERMISSION AND IS RETURNABLE UPON REQUEST.

NO.	DESCRIPTION	DATE
1	ADDENDUM-01	02/25/26

ISSUE DATE: **11/19/2025**  
SHEET NO.  
**F1.0**  
JOB NUMBER  
**IUSB2501**