

ADDENDUM



SECTION 00 91 11.02 - ADDENDUM 002

OWNER

INDIANA UNIVERSITY

PROJECT

**20222168 - BL143C - SOCIAL RESEARCH DOAS
UNIT REMODEL**

A/E PROJECT 5-6633

PURPOSE

**THIS ADDENDUM SHALL FORM PART OF THE
BIDDING DOCUMENTS. CHANGES, ADDITIONS,
CLARIFICATION OR DELETIONS HEREIN
SUPERSEDE THE DRAWINGS AND
SPECIFICATIONS. BIDDERS SHALL INCLUDE
ON THE PROPOSAL FORM
ACKNOWLEDGEMENT OF THE RECEIPT OF
THIS ADDENDUM.**

ARCHITECT-ENGINEER

**GMB
317.641.0674
WWW.GMB.COM**

ADDENDUM



GENERAL

1.1 Q&A (NEW)

Question: How is the aerosol-based duct sealant scope on sheet M1.2.04 typically achieved?

Answer: Contractor must coordinate the process with an application specialist. The website www.aeroseal.com has more information including a link to "Find a Pro" and videos of the application process. Note that products from other manufacturers may be acceptable; submittals will be reviewed during the construction phase to verify that the product and its performance are comparable.

END OF SECTION