



**20230515 – BL001 – Lowell E. Baier Hall – Replace Generator to Exterior
Addendum 3**

May 18, 2026

General Notifications

Modifications described herein shall be incorporated into the project documents. All other work described in the project documents shall remain unchanged.

Acknowledge receipt of this Addendum by noting it on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum is a part of the contract documents.

Bidding Questions and Answers

Question 1: In Addendum #2, it says the stone is to be split face buff color but the stone on the existing building is variegated chat sewn. Is this what is being requested?

Answer 1: Yes, Berkshire Ashlar as noted in the spec.

Question 2: The specs talk about the block to have integral waterproofing in the block and the mortar.

Answer 2: Yes, this is required.

Question 3: Can Bybee Stone become an accepted manufacturer?

Answer 3: Product data was not received, however Bybee Stone can be accepted as a substitute if they meet the requirements noted in the specification.

Changes to the Drawing

Sheet E601 Electrical Details & Schedules:

- a. Automatic Transfer Switch: Revise Interruption Rating (A) from 65,000 to 42,000.

End of ADDENDUM 3