

ADDENDUM 03

29-JUN-2026

SB840 – Wiekamp Hall Replace Cooling Tower
Indiana University – South Bend
IU 20250610

Mussett, Nicholas & Associates, Inc.
502 S. West St
Indianapolis, IN 46225
MNA Commission No.: 2026023

TO ALL HOLDERS OF PROCUREMENT DOCUMENTS

This Addendum forms a part of the Contract Documents and modifies the original Procurement Documents dated 04-JUN-2026 and any previously issued Addenda, as noted below.

RESPONSES TO QUESTIONS RECEIVED

- Item No. 1 There is not an existing conduit for temperature controls between Wiekamp Hall's basement and the cooling tower on top of the garage. Please clarify how are we supposed to get control wiring from Johnson's engine in the basement to the VFD's located on the roof next to the cooling tower.
- A. Controls conduit and cables are required to connect the JCI controller in the Wiekamp Hall mechanical room to the new cooling tower VFDs and isolation valves, per the latest JCI control drawings. The exact path is means and methods and can be coordinated during construction.

By: Andrew Wegeng

Attachments: None

END OF ADDENDUM 03