



INDIANA UNIVERSITY
CAPITAL PROJECTS

Addendum #1

Project: BL601 Memorial Stadium – Install Handrails in West Bowl
IU 20261418

Date: July 13, 2026

This Addendum, issued prior to bidding, alters, amends, corrects, or clarifies the Construction Bid Documents to the extent stated herein and does thereby become a part of the Construction Bid Documents, and will become part of the Contract Documents of the successful bidder. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

ADDITIONAL INFORMATION

Handrails:

1. Pipe-rail:

1.5"

1.9" O.D.

Alloy: 316

#4 Finish

2. Coring:

3" O.C. core drilled hole

4-1/2" deep

Set with 45 grout by Master builders or equal

End of Addendum No. 1