

ADDENDUM NO. 3

RE: Indiana University
Disability Services for Students Wells Library
Bloomington, IN

Project Number: IU Project No. 20128037
KDS No. 2012-03

Date: May 29, 2012

From: Kirkwood Design Studio, P.C.
113 E. 6th Street
Bloomington, IN 47408

To: Bidders

This Addendum modifies the Bidding Documents dated May 1, 2012 and will become part of the Contract Documents. Acknowledge receipt of this Addendum on Bid Form. Failure to do so may subject the Bidder to disqualification.

CHANGES TO SPECIFICATIONS:

1. Section 012300 – ALTERNATES
 - a. Revise Alternate Bids listed on Addendum No. 1 to “ALTERNATE BID NO. 5 & ALTERNATE BID NO. 6” as shown on new bid forms (Addendum No. 1) in lieu of “ALTERNATE BID NO. 4 & ALTERNATE BID NO.5.”
2. Section 087100 – FINISH HARDWARE
 - a. Revise Set #1 to add “(1) set head and jamb smoke seals 5050 NA & (1) Vertical Edge smoke seal 5070 NA”

CHANGES TO DRAWINGS:

1. Sheets A.103 THIRD FLOOR PLANS
 - a. Revise General Note ‘H’ (Addendum No. 1) to read “Provide four (4) three-tier lockers – 12”W x 18”D x 72”H like Ideal Products, Inc. Ideal 1000 Series Plastic Laminate Lockers, padlock hasps, two (2) finish end panels, color selection from manufacturers full range” in lieu of “Provide four (4) three-tier lockers – 12”W x 18”D x 72”H like Ideal Products, Inc. Ideal 1000 Series Plastic Laminate Lockers.”
 - b. Floor Plan ‘A’ - Revise wall between Reception Area 302 and Elevator Lobby 399G to be 1-hour rated wall construction, seal tight to deck.

END OF ADDENDUM